

# Quality Control Report

**Consultant** **Wahib Medanat** Consultant Engineers  
**Site Name** Khadija Bint Khwailed Basic Mixed - Balqa  
**Package** Package 1  
**Contractor** Derar Saraireh & Sons for Engineering & Contracting  
**Tender No.** 1/2020/USAID/SKEP/3/1

**Rep No.** QC-13 07  
**Date** 23 / 05 / 2021

Description of Non Conformance	Corrective Action	Required by / When
Defects in one column during the casting due to the concrete pump hitting the column	Checking the plumbing and review, chipping accordingly and use the approved material for finishing	The Contractor/Immediately
<b>Report Prepared by</b>		Hassan Shaqbua, Supervision Quality Control Manager
<b>Contractor's Response</b>		
The Contractor responded on 24/5/2021 and repaired under the supervision of consultant staff		
<b>Notes</b>		

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature



1- Defected Work

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature

# Quality Control Report



1- Corrective Action

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature

# Quality Control Report



2- Corrective Action

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature