

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name Khadija Bint Khwailed Basic Mixed - Balqa
Package Package 1
Contractor Derar Saraireh & Sons for Engineering & Contracting
Tender No. 1/2020/USAID/SKEP/3/1

Rep No. QC-13 06
Date 22 / 05 / 2021

Description of Non Conformance	Corrective Action	Required by / When
Segregation in roof slab on 22/05/2021	Chipping, cleaning and repair using approved material	Contractor/Immediately
Report Prepared by	Hassan Shaqbua, Supervision Quality Control Manager	

Contractor's Response

The Contractor responded on 23/5/2021 and repaired under the supervision of consultant staff	
Notes	

Consultant Site Engineer

Contractor Site Engineer

Signature

Signature

Quality Control Report



1- Defected Works

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature



2- Defected Work

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature

Quality Control Report



1- Corrective Action



2- Corrective Action

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature