

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name **Khadija Bint Khwailed Basic Mixed - Balqa**
Package **Package 1**
Contractor **Derar Saraireh & Sons for Engineering & Contracting**
Tender No. **1/2020/USAID/SKEP/3/1**

Rep No. **QC-13 10**
Date **17 / 10 / 2021**

Description of Non Conformance	Corrective Action	Required by / When
1. The Contractor has in stock boulders to be used for backfilling.	1. To be removed outside the site and to use complied backfilling.	The Contractor/Immediately
Report Prepared by	Hassan Shaqbua, Supervision Quality Control Manager	
Contractor's Response		
The Contractor still not responding.		
Notes		

Consultant Site Engineer

Contractor Site Engineer

Signature

Signature

Quality Control Report

Before Photos:



Boulders collected to be used by Contractor as backfilling material

Consultant Site Engineer

Signature

Contractor Site Engineer

Signature

Quality Control Report

Photos After:



Consultant Site Engineer

Signature

Contractor Site Engineer

Signature