

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name **Thahr Al Sarow Basic Boys - Jerash**
Package **Package 2**
Contractor **Dijlah Est. Construction Co.**
Tender No. **10/2019/USAID/SKEP/3/2**

Rep No. **QC-22 04**
Date **30 / 05 / 2021**

Description of Non Conformance	Corrective Action	Required by / When
Defects in building blocks at one elevation	Demolish the defected work and re-build	The Contractor/Immediately
Report Prepared by	Hassan Shaqbua, Supervision Quality Control Manager	
Contractor's Response		
The Contractor responded immediately		
Notes		

Consultant Site Engineer
Signature

Contractor Site Engineer

Signature

Quality Control Report



1- Defected Work



1- Corrective Action

Consultant Site Engineer
Signature

Contractor Site Engineer

Signature