

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name Khadija Bint Khwailed Basic Mixed - Balqa
Package Package 1
Contractor Derar Saraireh & Sons for Engineering & Contracting
Tender No. 1/2020/USAID/SKEP/3/1

Rep No. QC-13 05
Date 20 / 03 / 2021

Description of Non Conformance	Corrective Action	Required by / When
Minor segregation appeared in another part in western retaining wall.	Repair by using approved material.	immediate action by contractor.
<p align="center">Report Prepared by</p>	Hassan Shaqbua, Supervision Quality Control Manager	
<p align="center">Contractor's Response</p>		
Prompt action was taken by the contractor.		
<p align="center">Notes</p>		

Consultant Site Engineer

Contractor Site Engineer

Signature

Signature

Quality Control Report



Consultant Site Engineer

Signature

Contractor Site Engineer

Signature