

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name Hay Al Iskan Basic mixed - Jerash
Package Package 2
Contractor Dijlah Est. Construction Co.
Tender No. 10/2019/USAID/SKEP/3/2

Rep No. QC-21 02
Date 11 / 02 / 2021

Description of Non Conformance	Corrective Action	Required by / When
Minor segregation in boundary wall	Repair using approved materials	Contractor/ immediately
Report Prepared by	Hassan Shaqbua, Supervision Quality Control Manager	
Contractor's Response		
The contractor responded positively and promptly		
Notes		

Consultant Site Engineer

Contractor Site Engineer

Signature

Signature

Quality Control Report



Consultant Site Engineer

Signature

Contractor Site Engineer

Signature