

Quality Control Report

Consultant **Wahib Medanat** Consultant Engineers
Site Name **Khadija Bint Khwailed Basic Mixed - Balqa**
Package **Package 1**
Contractor **Derar Saraireh & Sons for Engineering & Contracting**
Tender No. **1/2020/USAID/SKEP/3/1**

Rep No. **QC-13 02**
Date **8 / 02 / 2021**

Description of Non Conformance	Corrective Action	Required by / When
<p>Minor and limited parts in the foundations with no separate blinding concrete layer as shown in the attached photo.</p>	<p>Removing shuttering, cleaning and casting blinding concrete and re- fix shuttering and finish as required.</p>	<p>Contractor, immediately.</p>
<p>Report Prepared by</p>	<p>Hassan Shaqbua, Supervision Quality Control Manager</p>	
<p>Contractor's Response</p>		
<p>The Contractor responded positively and promptly and executed as per the required process. Photos are attached.</p>		
<p>Notes</p>		

Consultant Site Engineer

Contractor Site Engineer

Signature

Signature

Quality Control Report



Consultant Site Engineer

Signature

Contractor Site Engineer

Signature

Quality Control Report



Consultant Site Engineer

Signature

Contractor Site Engineer

Signature